

Return address: P.O. Box 1090, 2280 CB Rijswijk, The Netherlands

Fiberplast BV  
Attn. Mr. Walter Wieten  
De Roef 7a  
9206 AK DRACHTEN

Centre for Fire Safety  
Lange Kleiweg 5  
P.O. Box 1090  
2280 CB Rijswijk

[www.efectis.nl](http://www.efectis.nl)

T +31 15 276 34 80  
F +31 15 276 30 25

**Subject**

Statement regarding burning droplets

Dear Mr. Wieten,

The Envirodeck products *Series Marine*, *Series Classic* and *Series Solid* from Fiberplast have all been tested at Efectis in relation to EN 13501-1 (EN ISO 11925-2 and EN ISO 9239-1).

As a part of the EN ISO 11925-2 testing, possible burning droplets shall be registered during the test. Efectis hereby confirm that no burning droplets appeared during this testing for any of the above product series.

During the EN ISO 9239-1 testing, registration of burning droplets is not part of the test requirement.

With kind regards,



Johnny Ostenfeldt, M.Sc.  
Head of Reaction to Fire Efectis Nederland

**Date**

20 January 2010

**Our reference**

2010-Efectis-B0012/OTJ/TNL

**E-mail**

[Johnny.Ostenfeldt@efectis.com](mailto:Johnny.Ostenfeldt@efectis.com)

**Direct dialling**

(015) 27 63290

**Direct fax**

(015) 27 63025

Efectis Nederland BV:  
a TNO Company

The Standard Conditions for Research Instructions given to TNO, as filed at the Registry of the District Court and the Chamber of Commerce in The Hague shall apply to all instructions given to Efectis; the Standard Conditions will be sent on request.